


RANDY TRANI  
 Superintendent  
 ROBIN LINDEEN-BLAKELEY  
 Deputy Clerk  
 SARAH JUDSON  
 Business Manager  
 DEEDEE HANES  
 K-5 Principal  
 PHILLIP PEARSON  
 Secondary Principal  
 LORI LUNA  
 CAPS Principal



**CORBETT SCHOOL DISTRICT  
 NO. 39**

35800 E. Historic Columbia River Highway  
 Corbett, Oregon 97019-9629

Administrative Office 503-261-4200  
 Grade School 503-261-4236  
 Middle/High School 503-261-4226  
 Fax 503-695-3641  
 CAPS 503-261-4294

## Results for Lead Testing in Corbett School Water

Water samples were submitted on 6/9/16 to Waterlab Corp. for lead testing. The results inform us that that the samples were below the level requiring action. The highest level was reported in the Science Lab sink. While it is still under the action level, and it is not from a drinking fountain, as a precautionary measure signs will be posted in the lab stating that the water is not potable.

### Lead Testing Results Summary

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008

Corbett School District

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter	Action Level, mg/liter***
6/9/16	20160609-08	Springdale East Drinking Fountain	ND @ 0.002	0.020
6/9/16	20160609 -09	GS Drinking Fountain, Gym	ND @ 0.002	0.020
6/9/16	20160609-10	HW Gym Drinking Fountain	ND @ 0.002	0.020
6/9/16	20160609- 11	Kitchen sink	0.0025	0.020
6/9/16	20160609-12	HS Drinking Fountain	ND @ 0.002	0.020
6/9/16	20160609-13	MS Drinking Fountain	0.0041	0.020
6/9/16	20160609-14	MS Boys Sink	0.0071	0.020
6/9/16	20160609-15	Girls Locker Drinking Fountain	0.0094	0.020
6/9/16	20160609-16	Science Lab Sink	0.0161	0.020
6/9/16	20160609-17	Boys Locker Rm Sink	0.0071	0.020

ND means No Detection at stated value.

\*\*\* Sample Size 1liter