

PIXIS Labs

Accurate. Reliable. On Time.

Pixis Labs

12423 NE Whitaker Way
Portland, OR 97230
503-254-1794

Job Number: 7021007
Report Date: 02/15/2017
ORELAP #: OR100028

Cover Letter

Mark Wilson
Corbett School Dist. 39
35800 E Hist. Col. Rv. Hwy.
CORBETT, OR 97015

Dear Mark Wilson,

Enclosed please find Pixis Labs analytical report for samples received as order number 7021007 on 02/10/2017. Should you have any questions about this report or any other matter, please do not hesitate to contact us. We are here to help you.

Test results relate only to the parameters tested and to the samples as received by the laboratory. Test results meet all requirements of NELAP and the Pixis quality assurance plan unless otherwise noted. This report shall not be reproduced, except in full, without the written consent of this laboratory. Samples will be kept a maximum of 15 days from the report date unless prior arrangements have been made.

Thank you for allowing Pixis to be of service to you, we appreciate your business.

Sincerely,

Signed
Richard Reid
Project Manager

Sample Results

Sample	Collected	Temp	Matrix
Sample: 1 GS Rm 14 sink	02/10/17 06:05	14 C	Drinking Water
Lab ID: 131024	Received: 02/10/17 11:30	Evidence of Cooling:N	
Analyte	Result	Limit Units MRL Dil.	Batch Start/Extract Analyzed Notes
Method: EPA 200.8			
Lead	0.0024	0.02 mg/L 0.0002 1	30788-7 02/13/17 14:29
Sample: 2 GS Rm 14 d fountain	02/10/17 06:05	14 C	Drinking Water
Lab ID: 131025	Received: 02/10/17 11:30	Evidence of Cooling:N	
Analyte	Result	Limit Units MRL Dil.	Batch Start/Extract Analyzed Notes
Method: EPA 200.8			
Lead	0.0007	0.02 mg/L 0.0002 1	30788-8 02/13/17 14:31
Sample: 3 GS E gym sink	02/10/17 06:40	14 C	Drinking Water
Lab ID: 131026	Received: 02/10/17 11:30	Evidence of Cooling:N	
Analyte	Result	Limit Units MRL Dil.	Batch Start/Extract Analyzed Notes
Method: EPA 200.8			
Lead	0.0002	0.02 mg/L 0.0002 1	30788-9 02/13/17 14:34
Sample: 4 GS E gym coach sink	02/10/17 06:45	14 C	Drinking Water
Lab ID: 131027	Received: 02/10/17 11:30	Evidence of Cooling:N	
Analyte	Result	Limit Units MRL Dil.	Batch Start/Extract Analyzed Notes
Method: EPA 200.8			
Lead	0.0026	0.02 mg/L 0.0002 1	30788-10 02/13/17 14:37
Sample: 5 GS rm 12 DF	02/10/17 06:15	14 C	Drinking Water
Lab ID: 131028	Received: 02/10/17 11:30	Evidence of Cooling:N	
Analyte	Result	Limit Units MRL Dil.	Batch Start/Extract Analyzed Notes
Method: EPA 200.8			
Lead	0.0009	0.02 mg/L 0.0002 1	30788-11 02/13/17 14:39
Sample: 6 GS rm 12 sink	02/10/17 06:15	14 C	Drinking Water
Lab ID: 131029	Received: 02/10/17 11:30	Evidence of Cooling:N	
Analyte	Result	Limit Units MRL Dil.	Batch Start/Extract Analyzed Notes
Method: EPA 200.8			
Lead	0.0025	0.02 mg/L 0.0002 1	30788-12 02/13/17 14:42
Sample: 7 GS rm 9 sink	02/10/17 06:40	14 C	Drinking Water
Lab ID: 131030	Received: 02/10/17 11:30	Evidence of Cooling:N	
Analyte	Result	Limit Units MRL Dil.	Batch Start/Extract Analyzed Notes
Method: EPA 200.8			
Lead	0.0022	0.02 mg/L 0.0002 1	30788-13 02/13/17 14:45
Sample: 8 GS rm 9 DF	02/10/17 06:40	14 C	Drinking Water
Lab ID: 131031	Received: 02/10/17 11:30	Evidence of Cooling:N	
Analyte	Result	Limit Units MRL Dil.	Batch Start/Extract Analyzed Notes
Method: EPA 200.8			

Lead	0.0003	0.02	mg/L	0.0002	1	30788-14	02/13/17 14:47		
Sample: 9 GS rm 13 sink		Collected: 02/10/17 06:10		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131032		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0027	0.02	mg/L	0.0002	1	30788-15	02/13/17 14:50		
Sample: 10 GS rm 13 DF		Collected: 02/10/17 06:10		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131033		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0005	0.02	mg/L	0.0002	1	30788-16	02/13/17 14:53		
Sample: 11 GS rm 16 sink		Collected: 02/10/17 06:00		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131034		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0014	0.02	mg/L	0.0002	1	30788-22	02/13/17 15:09		
Sample: 12 GS rm 16 DF		Collected: 02/10/17 06:00		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131035		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0004	0.02	mg/L	0.0002	1	30788-23	02/13/17 15:11		
Sample: 13 GS rm 10 sink		Collected: 02/10/17 06:30		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131036		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0045	0.02	mg/L	0.0002	1	30788-24	02/13/17 15:14		
Sample: 14 GS rm 10 DF		Collected: 02/10/17 06:30		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131037		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0006	0.02	mg/L	0.0002	1	30788-25	02/13/17 15:17		
Sample: 15 GS rm 15 sink		Collected: 02/10/17 06:05		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131038		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0023	0.02	mg/L	0.0002	1	30788-26	02/13/17 15:19		
Sample: 16 GS rm 15 DF		Collected: 02/10/17 06:05		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131039		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0004	0.02	mg/L	0.0002	1	30788-27	02/13/17 15:22		
Sample: 17 GS rm 8 sink		Collected: 02/10/17 06:22		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131040		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0035	0.02	mg/L	0.0002	1	30788-28	02/13/17 15:25		

Sample: 18 GS rm 8 DF		Collected: 02/10/17 06:22				Temp: 14 C		Matrix: Drinking Water	
Lab ID: 131041		Received: 02/10/17 11:30				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0004	0.02	mg/L	0.0002	1	30788-29		02/13/17 15:27	
Sample: 19 GS Staff rm sink		Collected: 02/10/17 06:51				Temp: 14 C		Matrix: Drinking Water	
Lab ID: 131042		Received: 02/10/17 11:30				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0006	0.02	mg/L	0.0002	1	30788-30		02/13/17 15:30	
Sample: 20 GS Nurses office sink		Collected: 02/10/17 06:56				Temp: 14 C		Matrix: Drinking Water	
Lab ID: 131043		Received: 02/10/17 11:30				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0011	0.02	mg/L	0.0002	1	30788-31		02/13/17 15:33	
Sample: 21 GS paper rm DF		Collected: 02/10/17 06:50				Temp: 14 C		Matrix: Drinking Water	
Lab ID: 131044		Received: 02/10/17 11:30				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0002	0.02	mg/L	0.0002	1	30788-36		02/13/17 15:46	
Sample: 22 GS Chui sink		Collected: 02/10/17 06:53				Temp: 14 C		Matrix: Drinking Water	
Lab ID: 131045		Received: 02/10/17 11:30				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0009	0.02	mg/L	0.0002	1	30788-37		02/13/17 15:49	
Sample: 23 GS rm 5 DF		Collected: 02/10/17 06:31				Temp: 14 C		Matrix: Drinking Water	
Lab ID: 131046		Received: 02/10/17 11:30				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0002	0.02	mg/L	0.0002	1	30788-38		02/13/17 15:52	
Sample: 24 GS rm 5 sink		Collected: 02/10/17 06:31				Temp: 14 C		Matrix: Drinking Water	
Lab ID: 131047		Received: 02/10/17 11:30				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0020	0.02	mg/L	0.0002	1	30788-39		02/13/17 15:54	
Sample: 25 GS staff R/R sink		Collected: 02/10/17 06:51				Temp: 14 C		Matrix: Drinking Water	
Lab ID: 131048		Received: 02/10/17 11:30				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0004	0.02	mg/L	0.0002	1	30788-40		02/13/17 15:57	
Sample: 26 GS rm 6 DF		Collected: 02/10/17 06:30				Temp: 14 C		Matrix: Drinking Water	
Lab ID: 131049		Received: 02/10/17 11:30				Evidence of Cooling:N			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0003	0.02	mg/L	0.0002	1	30788-41		02/13/17 16:00	

Sample: 27 GS rm 6 sink		Collected: 02/10/17 06:30		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131050		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0054	0.02	mg/L	0.0002	1	30788-42		02/13/17 16:02	
Sample: 28 GS rm 2 DF		Collected: 02/10/17 06:43		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131051		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0007	0.02	mg/L	0.0002	1	30788-43		02/13/17 16:05	
Sample: 29 GS rm 2 sink		Collected: 02/10/17 06:43		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131052		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0045	0.02	mg/L	0.0002	1	30788-44		02/13/17 16:08	
Sample: 30 GS Office RR sink		Collected: 02/10/17 06:55		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131053		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0007	0.02	mg/L	0.0002	1	30788-45		02/13/17 16:10	
Sample: 31 GS paper rm sink		Collected: 02/10/17 06:50		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131056		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0024	0.02	mg/L	0.0002	1	30788-50		02/13/17 16:24	
Sample: 32 GS Rm 11 DF		Collected: 02/10/17 06:25		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131057		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0005	0.02	mg/L	0.0002	1	30788-51		02/13/17 16:27	
Sample: 33 GS Rm 11 sink		Collected: 02/10/17 06:25		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131058		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0077	0.02	mg/L	0.0002	1	30788-52		02/13/17 16:29	
Sample: 34 GS Rm 3 sink		Collected: 02/10/17 06:45		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131059		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0042	0.02	mg/L	0.0002	1	30788-53		02/13/17 16:32	
Sample: 35 GS rm 3 DF		Collected: 02/10/17 06:45		Temp: 14 C		Matrix: Drinking Water			
Lab ID: 131060		Received: 02/10/17 11:30		Evidence of Cooling:N					
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0003	0.02	mg/L	0.0002	1	30788-54		02/13/17 16:35	

Sample: 36 GS rm 1 DF Lab ID: 131061		Collected: 02/10/17 06:39 Received: 02/10/17 11:30		Temp: 14 C Evidence of Cooling:N		Matrix: Drinking Water			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0005	0.02	mg/L	0.0002	1	30788-55		02/13/17 16:37	
Sample: 37 GS Rm 1 sink Lab ID: 131062		Collected: 02/10/17 06:39 Received: 02/10/17 11:30		Temp: 14 C Evidence of Cooling:N		Matrix: Drinking Water			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0020	0.02	mg/L	0.0002	1	30788-56		02/13/17 16:40	
Sample: 38 GS Rm 7 DF Lab ID: 131063		Collected: 02/10/17 06:23 Received: 02/10/17 11:30		Temp: 14 C Evidence of Cooling:N		Matrix: Drinking Water			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0007	0.02	mg/L	0.0002	1	30788-57		02/13/17 16:43	
Sample: 39 GS rm 7 sink Lab ID: 131064		Collected: 02/10/17 06:23 Received: 02/10/17 11:30		Temp: 14 C Evidence of Cooling:N		Matrix: Drinking Water			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0032	0.02	mg/L	0.0002	1	30788-58		02/13/17 16:45	
Sample: 40 GS Rm 4 sink Lab ID: 131065		Collected: 02/10/17 06:34 Received: 02/10/17 11:30		Temp: 14 C Evidence of Cooling:N		Matrix: Drinking Water			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0021	0.02	mg/L	0.0002	1	30788-59		02/13/17 16:48	
Sample: 41 GS rm 4 DF Lab ID: 131066		Collected: 02/10/17 06:34 Received: 02/10/17 11:30		Temp: 14 C Evidence of Cooling:N		Matrix: Drinking Water			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0004	0.02	mg/L	0.0002	1	30788-64		02/13/17 17:01	
Sample: 42 HS Beno lyon sink Lab ID: 131067		Collected: 02/10/17 07:30 Received: 02/10/17 11:30		Temp: 14 C Evidence of Cooling:N		Matrix: Drinking Water			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0069	0.02	mg/L	0.0002	1	30788-65		02/13/17 17:04	
Sample: 43 HS art rm sink Lab ID: 131068		Collected: 02/10/17 07:30 Received: 02/10/17 11:30		Temp: 14 C Evidence of Cooling:N		Matrix: Drinking Water			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0004	0.02	mg/L	0.0002	1	30788-66		02/13/17 17:07	
Sample: 44 HS lizio sink Lab ID: 131069		Collected: 02/10/17 07:31 Received: 02/10/17 11:30		Temp: 14 C Evidence of Cooling:N		Matrix: Drinking Water			
Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8									
Lead	0.0003	0.02	mg/L	0.0002	1	30788-67		02/13/17 17:09	

Sample	Lab ID	Location	Collected	Received	Temp	Evidence of Cooling	Matrix	Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Sample: 45 HS McNairy sink	131076		02/10/17 07:30	02/10/17 11:30	14 C	N	Drinking Water	Lead	0.0056	0.02	mg/L	0.0002	1	30788-68		02/13/17 17:12	
Method: EPA 200.8																	
Sample: 46 HS Lizio bath sink	131071		02/10/17 07:31	02/10/17 11:30	14 C	N	Drinking Water	Lead	0.0012	0.02	mg/L	0.0002	1	30788-69		02/13/17 17:15	
Method: EPA 200.8																	
Sample: 47 HS boys bath sink	131072		02/10/17 08:00	02/10/17 11:30	14 C	N	Drinking Water	Lead	0.0008	0.02	mg/L	0.0002	1	30788-70		02/13/17 17:17	
Method: EPA 200.8																	
Sample: 48 HS girls bath sink	131073		02/10/17 07:30	02/10/17 11:30	14 C	N	Drinking Water	Lead	0.0004	0.02	mg/L	0.0002	1	30788-71		02/13/17 17:20	
Method: EPA 200.8																	
Sample: 49 HS D moore sink	131074		02/10/17 07:35	02/10/17 11:30	14 C	N	Drinking Water	Lead	0.0008	0.02	mg/L	0.0002	1	30788-72		02/13/17 17:23	
Method: EPA 200.8																	
Sample: 50 HS drinking fountain	131075		02/10/17 08:00	02/10/17 11:30	14 C	N	Drinking Water	Lead	0.0003	0.02	mg/L	0.0002	1	30788-73		02/13/17 17:25	
Method: EPA 200.8																	
Sample: 51 HS brian estes sink	131076		02/10/17 07:32	02/10/17 11:30	14 C	N	Drinking Water	Lead	0.0078	0.02	mg/L	0.0002	1	30788-79		02/13/17 17:41	
Method: EPA 200.8																	
Sample: 52 HS Staff bath next to corner	131079		02/10/17 08:00	02/10/17 11:30	14 C	N	Drinking Water	Lead	0.0011	0.02	mg/L	0.0002	1	30788-80		02/13/17 17:44	
Method: EPA 200.8																	
Sample: 53 GS cafe girls bath sink	131080		02/10/17 08:30	02/10/17 11:30	14 C	N	Drinking Water	Lead	0.0011	0.02	mg/L	0.0002	1	30788-81		02/13/17 17:47	
Method: EPA 200.8																	
Sample: 54 HS cafe boys bath sink			02/10/17 08:30		14 C		Drinking Water										

Lab ID	Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
131081	Lead	0.0010	0.02	mg/L	0.0002	1	30788-82	02/13/17 17:49		
Method: EPA 200.8										
Sample: 55 GS cafe boys bath sink										
Lab ID: 131082										
131082	Lead	0.0014	0.02	mg/L	0.0002	1	30788-83	02/13/17 17:52		
Method: EPA 200.8										
Sample: 56 Snack shack sink										
Lab ID: 131083										
131083	Lead	0.0024	0.02	mg/L	0.0002	1	30788-84	02/13/17 17:55		
Method: EPA 200.8										
Sample: 57 GS D fountain cafe										
Lab ID: 131084										
131084	Lead	ND	0.02	mg/L	0.0002	1	30788-85	02/13/17 17:57		
Method: EPA 200.8										
Sample: 58 Science lab eyewash										
Lab ID: 131085										
131085	Lead	0.0093	0.02	mg/L	0.0002	1	30788-86	02/13/17 18:00		
Method: EPA 200.8										
Sample: 59 HS cafe girls bath sink										
Lab ID: 131086										
131086	Lead	0.0009	0.02	mg/L	0.0002	1	30788-87	02/13/17 18:03		
Method: EPA 200.8										
Sample: 60 Kitchen bath sink										
Lab ID: 131087										
131087	Lead	0.0010	0.02	mg/L	0.0002	1	30788-88	02/13/17 18:05		
Method: EPA 200.8										
Sample: 61 HS cafe D fountain										
Lab ID: 131088										
131088	Lead	ND	0.02	mg/L	0.0002	1	30788-93	02/13/17 18:19		
Method: EPA 200.8										
Sample: 62 Kitchen hand sink office										
Lab ID: 131089										
131089	Lead	0.0007	0.02	mg/L	0.0002	1	30788-94	02/13/17 18:22		
Method: EPA 200.8										
Sample: 63 Science sink										
Lab ID: 131090										

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8 Lead	0.0171	0.02	mg/L	0.0002	1	30788-95		02/13/17 18:24	

Sample: 64 Vista house sink
 Lab ID: 131091
 Collected: 02/10/17 09:00
 Received: 02/10/17 11:30
 Temp: 14 C
 Evidence of Cooling:N
 Matrix: Drinking Water

Analyte	Result	Limit	Units	MRL	Dil.	Batch	Start/Extract	Analyzed	Notes
Method: EPA 200.8 Lead	0.0184	0.02	mg/L	0.0002	1	30788-96		02/13/17 18:27	

Abbreviations

MRL Method Reporting Limit
 ND None Detected at or above the MRL
 Limit Maximum Contamination Level (Limit) - The water is considered safe for drinking if the analytical results are below this federal recommended action level.

Units of Measure:

mg/L Milligrams Per Liter

