



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425

Page 1 of 1

LEAD & COPPER RULE REPORT

Client Name: Corbett School District
35800 E. Historic Columbia River Hwy
Corbett, OR 97019

Reference Number: **21-22139**

Project: Corbett Grade School - Retest

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type:
Sample Purpose: Investigative or Other
County:

Analyst: bsp
Date Received: 6/15/2021
Report Date: 6/24/2021
Approved By: bj
Authorized by:


Thanh B Phan
Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
21_42084	6/14/2021	21860100-009DW21B - GS Room 16 Drinking Fountain	1030	LEAD	1.36	ppb	15	1	200.8	4072	
21_42085	6/14/2021	21860100-015DW21B - GS Room 13 Drinking Fountain	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_42086	6/14/2021	21860100-019DW21B - GS Room 11 Drinking Fountain	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_42087	6/14/2021	21860100-021DW21B - GS Room 10 Drinking Fountain	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_42088	6/14/2021	21860100-023DW21B - GS Room 9 Drinking Fountain	1030	LEAD	1.24	ppb	15	1	200.8	4072	
21_42089	6/14/2021	21860100-027SH21B - GS Office Restroom Shower	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_42090	6/14/2021	21860100-032DW21B - GS Room 8 Drinking Fountain	1030	LEAD	1.0	ppb	15	1	200.8	4072	
21_42091	6/14/2021	21860100-034DW21B - GS Room 7 Drinking Fountain	1030	LEAD	1.19	ppb	15	1	200.8	4072	
21_42092	6/14/2021	21860100-038DW21B - GS Room 5 Drinking Fountain	1030	LEAD	1.28	ppb	15	1	200.8	4072	
21_42093	6/14/2021	21860100-042DW21B - GS Room 3 Drinking Fountain	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_42094	6/14/2021	21860100-046DW21B - GS Room 1 Drinking Fountain	1030	LEAD	3.23	ppb	15	1	200.8	4072	
21_42095	6/14/2021	21860100-052SF21A - GS Room Outside Principal's Office	1030	LEAD	ND	ppb	15	1	200.8	4072	

NOTES:

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.