

Burlington, WA Corporate Laboratory (a) 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 - 360,757,1400

Bellingham, WA Microbiology (b)

Portland, OR Microbiology/Chemistry (c) 9150 SW Pioneer CI SIe W - Wilsonville OR 97070 - 503 682 7802

Corvallis, OR Microbiology/Chemistry (d) 1100 NE Circle Blvd Ste 130 - Corvallis, OR 97330 - 541,753,4946

Bend, OR Microbiology (e) 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541 639 8425

Page 1 of 1

LEAD & COPPER RULE REPORT

Client Name: Corbett School District

35800 E. Historic Columbia River Hwy

Corbett, OR 97019

Reference Number: 21-22151

Project: Corbett High School

-Retest

System Name:

System ID Number:

DWP Source Number:

Multiple Sources:

Sample Type:

Sample Purpose: Investigative or Other

County:

Analyst: bsp

Date Received: 6/15/2021

Report Date: 6/24/2021

Approved By: bj

Authorized by:

Thanh B Phan Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA#	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
21_42120	6/14/2021	21860104-009CF21B - HS Classroom 16 Sink	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_42121	6/14/2021	21860104-017CF21B - HS Classroom 18 Left Sink	1030	LEAD	ND	ppb	15	1	200.8	4072	
21_42122	6/14/2021	21860104-019DW21B - HS Classroom Commons	1030	LEAD	1.31	ppb	15	1	200.8	4072	
21_42123	6/14/2021	21860104-020CF21B - HS Classroom 20 Left Sink	1030	LEAD	ND	ppb	15	1	200.8	4072	

NOTES:

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.