



Burlington, WA *Corporate Laboratory (a)*  
 1501 S. Walnut St. - Burlington, WA 98223 - 800.755.8235 - 360.717.1400  
 Bellingham, WA *Microbiology (b)*  
 2855 Douglas Dr. Ste 4 - Bellingham, WA 98225 - 360.715.7212

Portland, OR *Microbiology/Chemistry (c)*  
 9725 SW Concession Cr. Ste. A2 - Wilsonville, OR 97150 - 503.682.7802  
 Corvallis, OR *Microbiology/Chemistry (d)*  
 1700 NE Circle Blvd. Ste. 100 - Corvallis, OR 97331 - 541.753.4444  
 Bend, OR *Microbiology (e)*  
 20332 Emmons Blvd. Ste. 4 - Bend, OR 97701 - 541.639.8445

## LEAD & COPPER RULE REPORT

Client Name: Corbett School District  
 35800 E. Historic Columbia River Hwy  
 Corbett, OR 97019

Reference Number: **21-40795**  
 Project: Corbett HS Gym  
 Concession Sink - Retest

System Name:  
 System ID Number:  
 DWP Source Number:  
 Multiple Sources:  
 Sample Type:  
 Sample Purpose: Investigative or Other  
 County:

Analyst: bj  
 Date Received: 10/26/2021  
 Report Date: 11/2/2021  
 Approved By: anp  
 Authorized by:

Thanh B Phan  
 Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
21_78574	10/21/2021	21860105-008SF21C - HS Front Gym Concession Sink	1030	LEAD	2.4	ppb	15	1	200.8	4072	

**NOTES:**

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L (15 ppb) for Lead and 1.3 mg/L (1300 ppb) for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Thanh B Phan at the above phone number.